

Lab EPA ID No.: ID00912	Lab Sample#: 235705
Date Received: 11/23/2021	Date Reported by Lab: 12/13/21
Compliance or Replacement Sample: Compliance	
Date Collected: 11/23/2021	Time Collected: 08:15
Sample Type: Plant Tap	
PWS No.: 1090131 RE	PWS Name: Southside Water & Sewer
Sampling Location: Wellhouse Manifold	Tag#
Collector: Brad White	Phone: (208) 290-5484

Laboratory Name:  
**Accurate Testing Labs, LLC**  
 7950 Meadowlark Way  
 Coeur d'Alene, ID 83815  
 Phone (208) 762 8378  
 Fax (208) 762 9082  
 Web site: www.accuratetesting.com  
 E-mail: info@accuratetesting.com


Lab Order No.: **202110441** 1

**Public Drinking Water System INORGANIC CHEMICAL (IOC) ANALYSIS REPORT:**

Phase II								Phase V							
FRDS	Analytes	Results	MCL*	MDL*	Method	Analysis Date	Analyst	FRDS	Analytes	Results	MCL*	MDL*	Method	Analysis Date	Analyst
1010	Barium	0.026	2.0	0.02	EPA 200.7	12/09/21	WM	1036	Nickel	ND	0.10	0.005	EPA 200.7	12/09/21	WM
1015	Cadmium	ND	0.001	0.001	EPA 200.7	12/09/21	WM	1074	Antimony	ND	0.006	0.003	EPA 200.9	12/07/21	WM
1020	Chromium	ND	0.10	0.007	EPA 200.7	12/09/21	WM	1075	Beryllium	ND	0.004	0.003	EPA 200.7	12/09/21	WM
1035	Mercury	ND	0.002	0.000	EPA 245.1	12/09/21	WM	1085	Thallium	ND	0.002	0.001	EPA 200.9	12/08/21	WM
1038	NO2/NO3	1.3	10.0	0.1	EPA 300.0	11/24/21	WM	<i>Other IOCs</i>							
1040	Nitrate-N	1.3	10.0	0.1	EPA 300.0	11/23/21	WM	1005	Arsenic	ND	0.010	0.001	EPA 200.9	12/06/21	WM
1041	Nitrite-N	ND	1	0.1	EPA 300.0	11/23/21	WM	1025	Fluoride	ND	4.0	0.1	EPA 300.0	11/23/21	WM
1045	Selenium	ND	0.050	0.002	EPA 200.9	12/07/21	WM	1052	Sodium	5.01	500	0.3	EPA 200.7	12/13/21	WM
1024	Cyanide														
<i>Secondary IOCs (optional)</i>															
1002	Aluminum							1055	Sulfate	12.2	250	0.3	EPA 300.0	11/23/21	WM
1003	Ammonia							1095	Zinc						
1016	Calcium							1905	Color						
1017	Chloride							1915	Hardness						
1022	Copper							1920	Odor						
1027	Hyd. Sulfide							1925	pH						
1028	Iron							1926	Conductivity						
1031	Magnesium							1927	Alkalinity						
1032	Manganese							1930	Diss. Solids						
1042	Postassium							1997	Langlier Indx						
1049	Silica SiO2							2905	Surfactants						
1050	Silver							1030	Lead						

\*Reported in mg/L unless otherwise noted, units differ for secondary MCLs depending on contaminant  
 ND = Not detected within sensitivity of instrument  
 Empty = No analysis performed for this contaminant  
 MDL = Method detection limit  
 MCL - Maximum Contaminant Level

Comments:



12/13/21

Southside Water & Sewer

P. O. Box D  
 Sandpoint, ID 83864

Laboratory  
 Supervisor,  
 Digitally signed by:  
 Walter Mueller